

### K525 WEST WESTFIELD SOLE WATER SUPPLY ZONE

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
ALUMINIUM	ugAl/l	200	24	<6.9	13.275	15.5	0
AMMONIUM (AMMONIA AND AMMONIUM IONS)	mgNH4/l	0.5	8	<0.01	<0.01	<0.01	0
ANTIMONY	ugSb/l	5	8	0.13	0.1925	0.32	0
ARSENIC	ugAs/l	10	8	0.16	0.22375	0.28	0
BENZO A PYRENE	ug/l	0.01	8	<0.00042	0.00046	0.00057	0
CADMIUM	ugCd/l	5	8	<0.03	<0.03	<0.03	0
CHROMIUM	ugCr/l	50	8	<0.18	0.35875	0.48	0
COLIFORM BACTERIA	Number/100ml	0	36	0	0	0	0
COLONY COUNT @ 22 C	Number/1ml	No Abnormal Change	24	0	1.125	17	0
COLOUR	mg/l Pt/Co	20	24	<3	<3	<3	0
COPPER	mgCu/l	2	8	0.0018	0.01761	0.0742	0
E.COLI	Number/100ml	0	36	0	0	0	0
ENTEROCOCCI	Number/100ml	0	8	0	0	0	0
FREE CHLORINE	mg/l as Cl2		36	<0.04	0.1625	0.36	0
HYDROGEN ION (PH)	pH value	6.5 - 9.5	24	7.22	7.43458	7.6	0
IRON	ugFe/l	200	24	3.92	21.09375	98	0
LEAD	ugPb/l	10	8	<0.04	0.0475	0.08	0
MANGANESE	ugMn/l	50	24	0.61	1.6975	4.78	0
NICKEL	ugNi/l	20	8	1.2	1.94625	3.9	0
NITRATE	mgNO3/l	50	8	16.9	20.5875	23.1	0
NITRITE	mgNO2/l	0.5	8	<0.002	0.00288	0.003	0
NITRITE/NITRATE FORMULA	Number	1	8	0.34	0.4125	0.46	0
ODOUR	Diln. No.	No Abnormal Change	24	0	0	0	0
PAH - SUM OF 4 SUBSTANCES	ug/l	0.1	8	0	0.00011	0.0009	0
SELENIUM	ugSe/l	10	8	<0.32	0.38375	0.5	0
SODIUM	mgNa/l	200	8	22	28.7625	41.2	0
TASTE	Diln. No.	No Abnormal Change	24	0	0	0	0
TERACHLOROETHENE/TRICHLOROETHENE SUM	ug/l	10	8	0	0	0	0
TETRACHLOROMETHANE	ug/l	3	8	<0.16	<0.16	<0.16	0
TOTAL CHLORINE	mg/l as Cl2		36	0.11	0.24528	0.46	0
TRIHALOMETHANES (SUM OF IDENTIFIED THMS)	ug/l	100	8	23.53	32.59375	38.88	0
TURBIDITY	NTU	4	24	<0.13	0.195	0.51	0

**LOWER BUSH CUXTON WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
1,2 DICHLOROETHANE	ug/l	3	8	<0.16	<0.16	<0.16	0
ALDRIN	ug/l	0.03	8	<0.008	<0.008	<0.008	0
ATRAZINE	ug/l	0.1	8	<0.004	0.0045	0.006	0
BENTAZONE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
BENZENE	ug/l	1	8	<0.06	<0.06	<0.06	0
BORON	mgB/l	1	8	<0.0319	<0.0319	<0.0319	0
BROMATE	ugBr03/l	10	8	<0.1	0.37625	1	0
CARBENDAZIM	ug/l	0.1	8	<0.005	<0.005	<0.005	0
CHLORIDE	mgCl/l	250	8	22.3	22.7375	24	0
CHLORTOLURON	ug/l	0.1	8	<0.005	0.0065	0.007	0
CLOSTRIDIUM PERFRINGENS	Number/100ml	0	8	0	0	0	0
COLIFORM BACTERIA	Number/100ml	0	98	0	0	0	0
COLONY COUNT @ 22 C	Number/1ml	No Abnormal Change	98	0	0.12245	2	0
CONDUCTIVITY	uS/cm	2500	23	516	546.73913	576	0
CYANIDE	ugCN/l	50	8	<1.2	<1.2	<1.2	0
DIAZINON	ug/l	0.1	8	<0.007	<0.007	<0.007	0
DIELDRIN	ug/l	0.03	8	<0.009	<0.009	<0.009	0
E.COLI	Number/100ml	0	98	0	0	0	0
FLUORIDE	mgF/l	1.5	8	0.1	0.11	0.13	0
FLUTRIAFOL	ug/l	0.1	8	<0.005	<0.005	<0.005	0
FREE CHLORINE	mg/l as Cl2		98	0.44	0.64296	0.9	0
GROSS ALPHA	Bq/l	0.1	8	<0.021	0.02913	0.034	0
GROSS BETA	Bq/l	1	8	0.049	0.05863	0.08	0
HEPTACHLOR	ug/l	0.03	8	<0.005	<0.005	<0.005	0
HEPTACHLOR EPOXIDE	ug/l	0.03	8	<0.007	<0.007	<0.007	0
MERCURY	ugHg/l	1	8	<0.04	0.045	0.06	0
METALDEHYDE	ug/l	0.1	8	<0.007	<0.007	<0.007	0
NITRITE	mgNO2/l	0.5	8	<0.002	0.0025	0.003	0
PESTICIDES - TOTAL SUBSTANCES	ug/l	0.5	8	0	0	0	0
PICLORAM	ug/l	0.1	8	<0.016	<0.016	<0.016	0
PROMETRYN	ug/l	0.1	8	<0.004	0.00425	0.005	0
PROPAZINE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
PROPYZAMIDE	ug/l	0.1	8	<0.009	<0.009	<0.009	0
SIMAZINE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
SULPHATE	mgSO4/l	250	8	20.9	21.55	22.6	0
TOTAL CHLORINE	mg/l as Cl2		98	0.41	0.65071	0.91	0
TOTAL ORGANIC CARBON	mgC/l	No Abnormal Change	8	<0.7	<0.7	<0.7	0
TRIFLURAZINE	ug/l	0.1	8	<0.004	0.00425	0.005	0

**LOWER BUSH CUXTON WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
TURBIDITY	NTU	1	98	<0.13	0.15878	0.46	0

**DANAWAY WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
1,2 DICHLOROETHANE	ug/l	3	7	<0.16	<0.16	<0.16	0
ALDRIN	ug/l	0.03	8	<0.008	<0.008	<0.008	0
ATRAZINE	ug/l	0.1	8	<0.004	0.0045	0.006	0
BENZENE	ug/l	1	7	<0.06	<0.06	<0.06	0
BORON	mgB/l	1	7	<0.0319	<0.0319	<0.0319	0
BROMACIL	ug/l	0.1	8	<0.011	0.014	0.015	0
BROMATE	ugBr03/l	10	7	0.3	0.75714	1.03	0
CARBENDAZIM	ug/l	0.1	8	<0.005	<0.005	<0.005	0
CHLORIDE	mgCl/l	250	7	32.3	33.15714	34.5	0
CHLORTOLURON	ug/l	0.1	8	<0.005	0.0065	0.007	0
CLOSTRIDIUM PERFRINGENS	Number/100ml	0	7	0	0	0	0
COLIFORM BACTERIA	Number/100ml	0	95	0	0	0	0
COLONY COUNT @ 22 C	Number/1ml	No Abnormal Change	95	0	0.30526	12	0
CONDUCTIVITY	uS/cm	2500	22	556	589.27273	621	0
CYANAZINE	ug/l	0.1	8	<0.004	0.00475	0.007	0
CYANIDE	ugCN/l	50	7	<1.2	<1.2	<1.2	0
DIELDRIN	ug/l	0.03	8	<0.009	<0.009	<0.009	0
E.COLI	Number/100ml	0	95	0	0	0	0
FENPROPIMORPH	ug/l	0.1	8	<0.01	<0.01	<0.01	0
FLUORIDE	mgF/l	1.5	7	0.09	0.09571	0.1	0
FLUTRIAFOL	ug/l	0.1	8	<0.005	<0.005	<0.005	0
FREE CHLORINE	mg/l as Cl2		95	0.1	0.35642	0.48	0
GLYPHOSATE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
HEPTACHLOR	ug/l	0.03	8	<0.005	<0.005	<0.005	0
HEPTACHLOR EPOXIDE	ug/l	0.03	8	<0.007	<0.007	<0.007	0
MCPA	ug/l	0.1	8	<0.006	<0.006	<0.006	0
MEPIQUAT CHLORIDE	ug/l	0.1	8	<0.004	0.005	0.008	0
MERCURY	ugHg/l	1	7	<0.04	0.04857	0.06	0
METALDEHYDE	ug/l	0.1	8	<0.007	0.00963	0.028	0
NITRITE	mgNO2/l	0.5	7	<0.002	0.00271	0.003	0
PESTICIDES - TOTAL SUBSTANCES	ug/l	0.5	9	0	0	0	0
PROMETRYN	ug/l	0.1	8	<0.004	0.00425	0.005	0
PROPAZINE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
SIMAZINE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
SPIROXAMINE	ug/l	0.1	8	<0.005	0.006	0.009	0
SULPHATE	mgSO4/l	250	7	8.94	9.58	9.94	0
TOTAL CHLORINE	mg/l as Cl2		95	0.11	0.36295	0.63	0
TOTAL ORGANIC CARBON	mgC/l	No Abnormal Change	7	<0.7	<0.7	<0.7	0

**DANAWAY WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
TRIAZINE	ug/l	0.1	8	<0.004	0.00425	0.005	0
TURBIDITY	NTU	1	95	<0.13	0.15126	0.38	0

**LONDON ROAD STROOD WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
1,2 DICHLOROETHANE	ug/l	3	8	<0.16	<0.16	<0.16	0
ALDRIN	ug/l	0.03	8	<0.008	<0.008	<0.008	0
ATRAZINE	ug/l	0.1	8	0.01	0.0105	0.011	0
BENZENE	ug/l	1	8	<0.06	<0.06	<0.06	0
BORON	mgB/l	1	8	0.051	0.05626	0.0593	0
BROMACIL	ug/l	0.1	8	<0.011	0.014	0.015	0
BROMATE	ugBr03/l	10	8	<0.1	0.145	0.2	0
CARBENDAZIM	ug/l	0.1	8	<0.005	<0.005	<0.005	0
CHLORIDE	mgCl/l	250	8	53	54.0625	55.1	0
CHLORMEQUAT	ug/l	0.1	8	<0.003	0.00425	0.008	0
CLOSTRIDIUM PERFRINGENS	Number/100ml	0	8	0	0	0	0
COLIFORM BACTERIA	Number/100ml	0	52	0	0	0	0
COLONY COUNT @ 22 C	Number/1ml	No Abnormal Change	52	0	0.13462	2	0
CONDUCTIVITY	uS/cm	2500	12	636	731.58333	767	0
CYANAZINE	ug/l	0.1	8	<0.004	0.00475	0.007	0
CYANIDE	ugCN/l	50	8	<1.2	<1.2	<1.2	0
DICAMBA	ug/l	0.1	8	<0.012	<0.012	<0.012	0
DIELDRIN	ug/l	0.03	8	<0.009	<0.009	<0.009	0
DIURON	ug/l	0.1	8	<0.008	0.00825	0.009	0
E.COLI	Number/100ml	0	52	0	0	0	0
EPOXICONAZOLE	ug/l	0.1	8	<0.005	0.00525	0.006	0
FLUORIDE	mgF/l	1.5	8	0.12	0.135	0.15	0
FLUTRIAFOL	ug/l	0.1	8	<0.005	<0.005	<0.005	0
FREE CHLORINE	mg/l as Cl2		52	0.51	0.81731	1.08	0
GLYPHOSATE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
GROSS ALPHA	Bq/l	0.1	8	<0.025	0.03175	0.041	0
GROSS BETA	Bq/l	1	8	0.109	0.12688	0.171	0
HEPTACHLOR	ug/l	0.03	8	<0.005	<0.005	<0.005	0
HEPTACHLOR EPOXIDE	ug/l	0.03	8	<0.007	<0.007	<0.007	0
MCPA	ug/l	0.1	8	<0.006	<0.006	<0.006	0
MERCURY	ugHg/l	1	8	<0.04	0.045	0.06	0
METALDEHYDE	ug/l	0.1	8	<0.007	0.00763	0.012	0
NITRITE	mgNO2/l	0.5	8	<0.002	0.00288	0.003	0
PESTICIDES - TOTAL SUBSTANCES	ug/l	0.5	8	0.019	0.02063	0.022	0
PICLORAM	ug/l	0.1	8	<0.016	0.018	0.032	0
PIRIMICARB	ug/l	0.1	8	<0.016	<0.016	<0.016	0
PROPAZINE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
PROPICONAZOLE	ug/l	0.1	8	<0.007	0.0075	0.009	0

**LONDON ROAD STROOD WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
QUINMERAC	ug/l	0.1	8	<0.006	0.00825	0.009	0
SIMAZINE	ug/l	0.1	8	0.009	0.01013	0.011	0
SPIROXAMINE	ug/l	0.1	8	<0.005	0.006	0.009	0
SULPHATE	mgSO4/l	250	8	39.3	41.2875	43.4	0
TEBUCONAZOLE	ug/l	0.1	8	<0.005	0.00525	0.006	0
TOTAL CHLORINE	mg/l as Cl2		52	0.64	0.83981	1.09	0
TOTAL ORGANIC CARBON	mgC/l	No Abnormal Change	8	0.81	0.96375	1.13	0
TURBIDITY	NTU	1	52	<0.13	0.15192	0.4	0

**SNODHURST WALDESLADE WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
1,2 DICHLOROETHANE	ug/l	3	8	<0.16	<0.16	<0.16	0
2,4-D	ug/l	0.1	8	<0.011	<0.011	<0.011	0
ALDRIN	ug/l	0.03	8	<0.008	<0.008	<0.008	0
ATRAZINE	ug/l	0.1	8	0.019	0.021	0.023	0
BENZENE	ug/l	1	8	<0.06	<0.06	<0.06	0
BORON	mgB/l	1	8	<0.0319	<0.0319	<0.0319	0
BROMACIL	ug/l	0.1	8	<0.011	0.014	0.015	0
BROMATE	ugBr03/l	10	8	<0.1	0.125	0.2	0
CARBENDAZIM	ug/l	0.1	8	<0.005	<0.005	<0.005	0
CHLORIDE	mgCl/l	250	8	29.7	31.05	32.4	0
CLOSTRIDIUM PERFRINGENS	Number/100ml	0	8	0	0	0	0
COLIFORM BACTERIA	Number/100ml	0	104	0	0	0	0
COLONY COUNT @ 22 C	Number/1ml	No Abnormal Change	104	0	0.29808	3	0
CONDUCTIVITY	uS/cm	2500	24	559	586.45833	612	0
CYANAZINE	ug/l	0.1	8	<0.004	0.00475	0.007	0
CYANIDE	ugCN/l	50	8	<1.2	<1.2	<1.2	0
DIAZINON	ug/l	0.1	8	<0.007	<0.007	<0.007	0
DIELDRIN	ug/l	0.03	8	<0.009	<0.009	<0.009	0
DIURON	ug/l	0.1	8	<0.008	0.00825	0.009	0
E.COLI	Number/100ml	0	104	0	0	0	0
EPOXICONAZOLE	ug/l	0.1	8	<0.005	0.00525	0.006	0
FLUFENACET	ug/l	0.1	8	<0.008	<0.008	<0.008	0
FLUORIDE	mgF/l	1.5	8	0.09	0.09875	0.1	0
FLUTRIAFOL	ug/l	0.1	8	0.011	0.0125	0.014	0
FREE CHLORINE	mg/l as Cl2		105	0.32	0.62905	0.78	0
GLYPHOSATE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
GROSS ALPHA	Bq/l	0.1	8	<0.021	0.02888	0.036	0
GROSS BETA	Bq/l	1	8	0.019	0.02913	0.036	0
HEPTACHLOR	ug/l	0.03	8	<0.005	<0.005	<0.005	0
HEPTACHLOR EPOXIDE	ug/l	0.03	8	<0.007	<0.007	<0.007	0
MECOPROP	ug/l	0.1	8	<0.009	<0.009	<0.009	0
MERCURY	ugHg/l	1	8	<0.04	0.0475	0.06	0
METALDEHYDE	ug/l	0.1	8	<0.007	0.00963	0.028	0
NITRITE	mgNO2/l	0.5	8	<0.002	0.00288	0.003	0
PENDIMETHALIN	ug/l	0.1	8	<0.009	<0.009	<0.009	0
PESTICIDES - TOTAL SUBSTANCES	ug/l	0.5	8	0.041	0.04438	0.049	0
PIRIMICARB	ug/l	0.1	8	<0.016	<0.016	<0.016	0
PROPazine	ug/l	0.1	8	<0.005	<0.005	<0.005	0



**SNODHURST WALDESLADE WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
PROPYZAMIDE	ug/l	0.1	8	<0.009	<0.009	<0.009	0
QUINMERAC	ug/l	0.1	8	<0.006	0.00825	0.009	0
SIMAZINE	ug/l	0.1	8	0.01	0.01088	0.012	0
SULPHATE	mgSO4/l	250	8	10.3	11.4	12.5	0
TOTAL CHLORINE	mg/l as Cl2		105	0.32	0.646	0.88	0
TOTAL ORGANIC CARBON	mgC/l	No Abnormal Change	8	<0.7	<0.7	<0.7	0
TRIAZINE	ug/l	0.1	8	<0.004	0.00425	0.005	0
TURBIDITY	NTU	1	105	<0.13	0.1519	0.48	0

**NASHENDEN CHATHAM WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
1,2 DICHLOROETHANE	ug/l	3	8	<0.16	<0.16	<0.16	0
ALDRIN	ug/l	0.03	8	<0.008	<0.008	<0.008	0
ATRAZINE	ug/l	0.1	8	0.004	0.006	0.007	0
BENTAZONE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
BENZENE	ug/l	1	8	<0.06	<0.06	<0.06	0
BORON	mgB/l	1	8	0.0248	0.03101	0.0319	0
BROMACIL	ug/l	0.1	8	<0.011	0.014	0.015	0
BROMATE	ugBr03/l	10	8	<0.15	0.24	0.32	0
CARBETAMIDE	ug/l	0.1	8	<0.009	0.012	0.013	0
CHLORIDE	mgCl/l	250	8	33.7	36.4375	39.5	0
CHLORMEQUAT	ug/l	0.1	8	<0.003	0.00425	0.008	0
CLOSTRIDIUM PERFRINGENS	Number/100ml	0	8	0	0	0	0
COLIFORM BACTERIA	Number/100ml	0	104	0	0	0	0
COLONY COUNT @ 22 C	Number/1ml	No Abnormal Change	104	0	0.15385	2	0
CONDUCTIVITY	uS/cm	2500	24	566	597.70833	632	0
CYANAZINE	ug/l	0.1	8	<0.004	0.00475	0.007	0
CYANIDE	ugCN/l	50	8	<1.2	<1.2	<1.2	0
DIELDRIN	ug/l	0.03	8	<0.009	<0.009	<0.009	0
DIURON	ug/l	0.1	8	<0.008	0.00825	0.009	0
E.COLI	Number/100ml	0	104	0	0	0	0
FENPROPIMORPH	ug/l	0.1	8	<0.01	<0.01	<0.01	0
FLUORIDE	mgF/l	1.5	8	0.1	0.1125	0.13	0
FLUTRIAFOL	ug/l	0.1	8	<0.005	0.00575	0.007	0
FREE CHLORINE	mg/l as Cl2		104	0.46	0.71192	0.88	0
HEPTACHLOR	ug/l	0.03	8	<0.005	<0.005	<0.005	0
HEPTACHLOR EPOXIDE	ug/l	0.03	8	<0.007	<0.007	<0.007	0
ISOPROTURON	ug/l	0.1	8	<0.005	<0.005	<0.005	0
MERCURY	ugHg/l	1	8	<0.04	0.045	0.06	0
METALDEHYDE	ug/l	0.1	8	<0.006	0.00688	0.007	0
NITRITE	mgNO2/l	0.5	8	<0.002	0.00263	0.003	0
PENDIMETHALIN	ug/l	0.1	8	<0.009	<0.009	<0.009	0
PESTICIDES - TOTAL SUBSTANCES	ug/l	0.5	8	0	0.0105	0.02	0
PIRIMICARB	ug/l	0.1	8	<0.016	<0.016	<0.016	0
PROMETRYN	ug/l	0.1	8	<0.004	0.00425	0.005	0
PROPAZINE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
QUINMERAC	ug/l	0.1	8	<0.006	0.00825	0.009	0
SIMAZINE	ug/l	0.1	8	<0.005	0.00525	0.006	0
SPIROXAMINE	ug/l	0.1	8	<0.005	0.006	0.009	0

**NASHENDEN CHATHAM WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
SULPHATE	mgSO <sub>4</sub> /l	250	8	15.6	16.6625	17.9	0
TOTAL CHLORINE	mg/l as Cl <sub>2</sub>		104	0.48	0.73365	1.12	0
TOTAL ORGANIC CARBON	mgC/l	No Abnormal Change	8	<0.7	0.72625	0.91	0
TURBIDITY	NTU	1	104	<0.13	0.14154	0.3	0

**MATTS HILL HARTLIP WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
1,2 DICHLOROETHANE	ug/l	3	8	<0.16	<0.16	<0.16	0
ALDRIN	ug/l	0.03	8	<0.008	<0.008	<0.008	0
ATRAZINE	ug/l	0.1	8	<0.004	0.0045	0.006	0
BENTAZONE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
BENZENE	ug/l	1	8	<0.06	<0.06	<0.06	0
BORON	mgB/l	1	8	0.014	0.02966	0.0319	0
BROMATE	ugBr03/l	10	8	<0.1	0.1125	0.15	0
CARBENDAZIM	ug/l	0.1	8	<0.005	<0.005	<0.005	0
CHLORIDE	mgCl/l	250	8	19.8	20.3375	21.4	0
CLOPYRALID	ug/l	0.1	8	<0.011	<0.011	<0.011	0
CLOSTRIDIUM PERFRINGENS	Number/100ml	0	8	0	0	0	0
<b>COLIFORM BACTERIA</b>	<b>Number/100ml</b>	<b>0</b>	<b>365</b>	<b>0</b>	<b>0.00274</b>	<b>1</b>	<b>1</b>
COLONY COUNT @ 22 C	Number/1ml	No Abnormal Change	366	0	0.1612	4	0
CONDUCTIVITY	uS/cm	2500	52	498	530.73077	557	0
CYANIDE	ugCN/l	50	8	<1.2	<1.2	<1.2	0
DIELDRIN	ug/l	0.03	8	<0.009	<0.009	<0.009	0
DIURON	ug/l	0.1	8	<0.008	0.00825	0.009	0
E.COLI	Number/100ml	0	365	0	0	0	0
EPOXICONAZOLE	ug/l	0.1	8	<0.005	0.00525	0.006	0
FENPROPIMORPH	ug/l	0.1	8	<0.01	<0.01	<0.01	0
FLUFENACET	ug/l	0.1	8	<0.008	<0.008	<0.008	0
FLUORIDE	mgF/l	1.5	8	0.08	0.0875	0.09	0
FLUOROXYPYR	ug/l	0.1	8	<0.008	<0.008	<0.008	0
FLUTRIAFOL	ug/l	0.1	8	<0.005	<0.005	<0.005	0
FREE CHLORINE	mg/l as Cl2		368	0.47	0.75372	0.99	0
GLYPHOSATE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
GROSS ALPHA	Bq/l	0.1	8	<0.021	0.02838	0.033	0
GROSS BETA	Bq/l	1	8	0.018	0.03838	0.107	0
HEPTACHLOR	ug/l	0.03	8	<0.005	<0.005	<0.005	0
HEPTACHLOR EPOXIDE	ug/l	0.03	8	<0.007	<0.007	<0.007	0
MERCURY	ugHg/l	1	8	<0.04	0.045	0.06	0
METALDEHYDE	ug/l	0.1	8	<0.006	0.0095	0.028	0
METAZACHLOR	ug/l	0.1	8	<0.005	0.00575	0.006	0
NITRITE	mgNO2/l	0.5	8	<0.002	0.00275	0.003	0
PENDIMETHALIN	ug/l	0.1	8	<0.009	<0.009	<0.009	0
PESTICIDES - TOTAL SUBSTANCES	ug/l	0.5	9	0	0	0	0
PICLORAM	ug/l	0.1	8	<0.016	<0.016	<0.016	0
PROMETRYN	ug/l	0.1	8	<0.004	0.00425	0.005	0

**MATTS HILL HARTLIP WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
PROPAZINE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
PROPYZAMIDE	ug/l	0.1	8	<0.009	<0.009	<0.009	0
PROSULFOCARB	ug/l	0.1	9	<0.006	0.00933	0.012	0
QUINMERAC	ug/l	0.1	8	<0.006	0.00825	0.009	0
SIMAZINE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
SPIROXAMINE	ug/l	0.1	8	<0.005	0.006	0.009	0
SULPHATE	mgSO4/l	250	8	5.58	5.93375	6.37	0
TEBUCONAZOLE	ug/l	0.1	8	<0.005	0.00525	0.006	0
TERBUTRYN	ug/l	0.1	8	<0.004	0.00475	0.005	0
TOTAL CHLORINE	mg/l as Cl2		368	0.52	0.76652	1.41	0
TOTAL ORGANIC CARBON	mgC/l	No Abnormal Change	8	<0.7	<0.7	<0.7	0
TRIALATE	ug/l	0.1	8	<0.006	<0.006	<0.006	0
TURBIDITY	NTU	1	368	<0.13	0.15929	0.38	0

**LUTON WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
1,2 DICHLOROETHANE	ug/l	3	8	<0.16	<0.16	<0.16	0
2,4-D	ug/l	0.1	8	<0.011	<0.011	<0.011	0
ALDRIN	ug/l	0.03	8	<0.008	<0.008	<0.008	0
ATRAZINE	ug/l	0.1	8	0.005	0.00613	0.007	0
BENTAZONE	ug/l	0.1	8	<0.005	0.0065	0.007	0
BENZENE	ug/l	1	8	<0.06	<0.06	<0.06	0
BORON	mgB/l	1	8	0.0406	0.04403	0.0533	0
BROMACIL	ug/l	0.1	8	<0.011	0.014	0.015	0
BROMATE	ugBr03/l	10	8	<0.1	0.11875	0.15	0
CARBENDAZIM	ug/l	0.1	8	<0.005	<0.005	<0.005	0
CHLORIDE	mgCl/l	250	8	32.2	33.375	34.8	0
CLOSTRIDIUM PERFRINGENS	Number/100ml	0	8	0	0	0	0
COLIFORM BACTERIA	Number/100ml	0	208	0	0	0	0
COLONY COUNT @ 22 C	Number/1ml	No Abnormal Change	208	0	0.23558	5	0
CONDUCTIVITY	uS/cm	2500	52	548	661.96154	704	0
CYANAZINE	ug/l	0.1	8	<0.004	0.00475	0.007	0
CYANIDE	ugCN/l	50	8	<1.2	1.2625	1.5	0
DIAZINON	ug/l	0.1	8	<0.007	<0.007	<0.007	0
DIELDRIN	ug/l	0.03	8	<0.009	<0.009	<0.009	0
DIURON	ug/l	0.1	8	<0.008	0.00825	0.009	0
E.COLI	Number/100ml	0	208	0	0	0	0
FLUFENACET	ug/l	0.1	8	<0.008	<0.008	<0.008	0
FLUORIDE	mgF/l	1.5	8	0.09	0.09875	0.1	0
FLUTRIAFOL	ug/l	0.1	8	<0.005	<0.005	<0.005	0
FLUXAPYROXAD	ug/l	0.1	8	<0.009	0.00925	0.01	0
FREE CHLORINE	mg/l as Cl2		208	0.33	0.71553	0.9	0
GLYPHOSATE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
GROSS ALPHA	Bq/l	0.1	8	<0.024	0.03238	0.038	0
GROSS BETA	Bq/l	1	8	0.054	0.06363	0.077	0
HEPTACHLOR	ug/l	0.03	8	<0.005	<0.005	<0.005	0
HEPTACHLOR EPOXIDE	ug/l	0.03	8	<0.007	<0.007	<0.007	0
MECOPROP	ug/l	0.1	8	<0.009	<0.009	<0.009	0
MEPIQUAT CHLORIDE	ug/l	0.1	8	<0.004	0.005	0.008	0
MERCURY	ugHg/l	1	8	<0.04	0.0475	0.06	0
METALDEHYDE	ug/l	0.1	8	<0.007	0.00963	0.028	0
NITRITE	mgNO2/l	0.5	8	<0.003	<0.003	<0.003	0
PENDIMETHALIN	ug/l	0.1	8	<0.009	<0.009	<0.009	0
PESTICIDES - TOTAL SUBSTANCES	ug/l	0.5	8	0.006	0.012	0.014	0

**LUTON WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
PROMETRYN	ug/l	0.1	8	<0.004	0.00425	0.005	0
PROPAZINE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
PROSULFOCARB	ug/l	0.1	8	<0.006	0.009	0.01	0
QUINMERAC	ug/l	0.1	8	<0.006	0.00825	0.009	0
SIMAZINE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
SPIROXAMINE	ug/l	0.1	8	<0.005	0.006	0.009	0
SULPHATE	mgSO4/l	250	8	21.2	23.2125	28.5	0
TOTAL CHLORINE	mg/l as Cl2		208	0.57	0.73947	0.9	0
TOTAL ORGANIC CARBON	mgC/l	No Abnormal Change	8	<0.7	0.71	0.78	0
TRIAZINE	ug/l	0.1	8	<0.004	0.00425	0.005	0
TURBIDITY	NTU	1	208	<0.13	0.14841	0.47	0

**EASTLING WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
1,2 DICHLOROETHANE	ug/l	3	8	<0.16	<0.16	<0.16	0
2,4-D	ug/l	0.1	8	<0.011	<0.011	<0.011	0
ALDRIN	ug/l	0.03	8	<0.008	<0.008	<0.008	0
ATRAZINE	ug/l	0.1	8	<0.004	0.0045	0.006	0
BENAZOLIN	ug/l	0.1	8	<0.013	<0.013	<0.013	0
BENTAZONE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
BENZENE	ug/l	1	8	<0.06	<0.06	<0.06	0
BORON	mgB/l	1	8	0.0146	0.02974	0.0319	0
BOSCALID	ug/l	0.1	8	<0.008	<0.008	<0.008	0
BROMACIL	ug/l	0.1	8	<0.011	0.014	0.015	0
BROMATE	ugBr03/l	10	8	<0.07	0.10875	0.15	0
CARBENDAZIM	ug/l	0.1	8	<0.005	<0.005	<0.005	0
CHLORIDE	mgCl/l	250	8	22	22.9375	23.6	0
CHLORMEQUAT	ug/l	0.1	8	<0.003	0.00488	0.008	0
CHLORTOLURON	ug/l	0.1	8	<0.005	0.0065	0.007	0
CLOPYRALID	ug/l	0.1	8	<0.011	<0.011	<0.011	0
CLOSTRIDIUM PERFRINGENS	Number/100ml	0	8	0	0	0	0
COLIFORM BACTERIA	Number/100ml	0	365	0	0	0	0
COLONY COUNT @ 22 C	Number/1ml	No Abnormal Change	366	0	0.27049	52	0
CONDUCTIVITY	uS/cm	2500	104	502	552.52885	620	0
CYANAZINE	ug/l	0.1	8	<0.004	0.00475	0.007	0
CYANIDE	ugCN/l	50	8	<1.2	<1.2	<1.2	0
CYPROCONAZOLE	ug/l	0.1	8	<0.006	0.00675	0.007	0
DIAZINON	ug/l	0.1	8	<0.007	<0.007	<0.007	0
DICAMBA	ug/l	0.1	8	<0.012	<0.012	<0.012	0
DIELDRIN	ug/l	0.03	8	<0.009	<0.009	<0.009	0
DIFLUFENICAN	ug/l	0.1	8	<0.009	<0.009	<0.009	0
E.COLI	Number/100ml	0	365	0	0	0	0
EPOXICONAZOLE	ug/l	0.1	8	<0.005	0.00525	0.006	0
FENPROPIMORPH	ug/l	0.1	8	<0.01	<0.01	<0.01	0
FLUFENACET	ug/l	0.1	8	<0.008	<0.008	<0.008	0
FLUORIDE	mgF/l	1.5	8	0.08	0.09375	0.1	0
FLUOROXYPYR	ug/l	0.1	8	<0.008	<0.008	<0.008	0
FLUTRIAFOL	ug/l	0.1	8	<0.005	<0.005	<0.005	0
FLUXAPYROXAD	ug/l	0.1	8	<0.009	0.00925	0.01	0
FREE CHLORINE	mg/l as Cl2		368	0.34	0.67353	0.97	0
GLYPHOSATE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
GROSS ALPHA	Bq/l	0.1	8	<0.02	0.02738	0.034	0



**EASTLING WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
GROSS BETA	Bq/l	1	8	0.027	0.04025	0.056	0
HEPTACHLOR	ug/l	0.03	8	<0.005	<0.005	<0.005	0
HEPTACHLOR EPOXIDE	ug/l	0.03	8	<0.007	<0.007	<0.007	0
ISOPROTURON	ug/l	0.1	8	<0.005	<0.005	<0.005	0
LINURON	ug/l	0.1	8	<0.009	0.00975	0.01	0
MCPA	ug/l	0.1	8	<0.006	<0.006	<0.006	0
MCPB	ug/l	0.1	8	<0.008	<0.008	<0.008	0
MERCURY	ugHg/l	1	8	<0.04	0.0475	0.06	0
METALDEHYDE	ug/l	0.1	8	<0.007	<0.007	<0.007	0
METAZACHLOR	ug/l	0.1	8	<0.005	0.00575	0.006	0
METHABENZTHIAZURON	ug/l	0.1	8	<0.005	0.00525	0.006	0
NITRITE	mgNO2/l	0.5	8	<0.002	0.00263	0.003	0
PENDIMETHALIN	ug/l	0.1	8	<0.009	<0.009	<0.009	0
PESTICIDES - TOTAL SUBSTANCES	ug/l	0.5	8	0	0	0	0
PICLORAM	ug/l	0.1	8	<0.016	<0.016	<0.016	0
PIRIMICARB	ug/l	0.1	8	<0.016	<0.016	<0.016	0
PROMETRYN	ug/l	0.1	8	<0.004	0.00425	0.005	0
PROPAZINE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
PROPICONAZOLE	ug/l	0.1	8	<0.007	0.0075	0.009	0
PROSULFOCARB	ug/l	0.1	8	<0.006	0.009	0.01	0
QUINMERAC	ug/l	0.1	8	<0.006	0.00825	0.009	0
SIMAZINE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
SPIROXAMINE	ug/l	0.1	8	<0.005	0.006	0.009	0
SULPHATE	mgSO4/l	250	8	8.01	8.5775	8.86	0
TEBUCONAZOLE	ug/l	0.1	8	<0.005	0.00525	0.006	0
TERBUTRYN	ug/l	0.1	8	<0.004	0.00475	0.005	0
TOTAL CHLORINE	mg/l as Cl2		368	0.34	0.69568	0.98	0
TOTAL ORGANIC CARBON	mgC/l	No Abnormal Change	8	<0.7	<0.7	<0.7	0
TRICLOPYR	ug/l	0.1	8	<0.016	<0.016	<0.016	0
TRIAZINE	ug/l	0.1	8	<0.004	0.00425	0.005	0
TURBIDITY	NTU	1	367	<0.13	0.15308	0.45	0

**BUSH ROAD CUXTON WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
1,2 DICHLOROETHANE	ug/l	3	8	<0.16	<0.16	<0.16	0
2,4-D	ug/l	0.1	8	<0.011	<0.011	<0.011	0
ALDRIN	ug/l	0.03	8	<0.008	<0.008	<0.008	0
ATRAZINE	ug/l	0.1	8	<0.004	0.0045	0.006	0
BENTAZONE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
BENZENE	ug/l	1	8	<0.06	<0.06	<0.06	0
BORON	mgB/l	1	8	0.0172	0.03006	0.0319	0
BROMATE	ugBr03/l	10	8	<0.07	0.10875	0.15	0
CARBENDAZIM	ug/l	0.1	8	<0.005	<0.005	<0.005	0
CHLORIDE	mgCl/l	250	8	20.4	20.9375	21.3	0
CHLORTOLURON	ug/l	0.1	8	<0.005	0.0065	0.007	0
CLOPYRALID	ug/l	0.1	8	<0.011	<0.011	<0.011	0
CLOSTRIDIUM PERFRINGENS	Number/100ml	0	8	0	0	0	0
COLIFORM BACTERIA	Number/100ml	0	104	0	0.00962	1	1
COLONY COUNT @ 22 C	Number/1ml	No Abnormal Change	104	0	0.25	4	0
CONDUCTIVITY	uS/cm	2500	24	520	545.875	570	0
CYANIDE	ugCN/l	50	8	<1.2	<1.2	<1.2	0
DIAZINON	ug/l	0.1	8	<0.007	<0.007	<0.007	0
DIELDRIN	ug/l	0.03	8	<0.009	<0.009	<0.009	0
E.COLI	Number/100ml	0	104	0	0	0	0
EPOXICONAZOLE	ug/l	0.1	8	<0.005	0.00525	0.006	0
FENPROPIIMORPH	ug/l	0.1	8	<0.01	<0.01	<0.01	0
FLUORIDE	mgF/l	1.5	8	0.1	0.1025	0.11	0
FREE CHLORINE	mg/l as Cl2		104	0.3	0.68077	0.85	0
GROSS ALPHA	Bq/l	0.1	8	<0.021	0.03063	0.034	0
GROSS BETA	Bq/l	1	8	0.021	0.04788	0.078	0
HEPTACHLOR	ug/l	0.03	8	<0.005	<0.005	<0.005	0
HEPTACHLOR EPOXIDE	ug/l	0.03	8	<0.007	<0.007	<0.007	0
MCPB	ug/l	0.1	8	<0.008	<0.008	<0.008	0
MECOPROP	ug/l	0.1	8	<0.009	<0.009	<0.009	0
MERCURY	ugHg/l	1	8	<0.04	0.0475	0.06	0
METALDEHYDE	ug/l	0.1	8	<0.007	<0.007	<0.007	0
METHABENZTHIAZURON	ug/l	0.1	8	<0.005	0.00525	0.006	0
NITRITE	mgNO2/l	0.5	8	<0.002	0.00275	0.003	0
PESTICIDES - TOTAL SUBSTANCES	ug/l	0.5	8	0	0	0	0
PROPYZAMIDE	ug/l	0.1	8	<0.009	<0.009	<0.009	0
PROSULFOCARB	ug/l	0.1	8	<0.006	0.009	0.01	0
QUINMERAC	ug/l	0.1	8	<0.006	0.00825	0.009	0

**BUSH ROAD CUXTON WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
SIMAZINE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
SULPHATE	mgSO4/l	250	8	12.3	14.7	16.5	0
TERBUTRYN	ug/l	0.1	8	<0.004	0.00475	0.005	0
TOTAL CHLORINE	mg/l as Cl2		104	0.47	0.69115	0.88	0
TOTAL ORGANIC CARBON	mgC/l	No Abnormal Change	8	<0.7	0.70375	0.73	0
TRIFLUOROETHYLENE	ug/l	0.1	8	<0.004	0.00425	0.005	0
TURBIDITY	NTU	1	104	<0.13	0.15567	0.41	0

**BURHAM WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
1,2 DICHLOROETHANE	ug/l	3	8	<0.16	<0.16	<0.16	0
2,4-D	ug/l	0.1	8	<0.011	<0.011	<0.011	0
ALDRIN	ug/l	0.03	8	<0.008	<0.008	<0.008	0
BENTAZONE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
BENZENE	ug/l	1	8	<0.06	<0.06	<0.06	0
BORON	mgB/l	1	8	0.0415	0.05458	0.0653	0
BOSCALID	ug/l	0.1	8	<0.008	<0.008	<0.008	0
BROMATE	ugBr03/l	10	8	0.4	1.5925	2.95	0
CARBENDAZIM	ug/l	0.1	8	<0.005	<0.005	<0.005	0
CARBETAMIDE	ug/l	0.1	8	<0.009	0.0125	0.013	0
CHLORIDE	mgCl/l	250	8	28.3	40.025	47.7	0
CHLORMEQUAT	ug/l	0.1	8	<0.003	0.00425	0.008	0
CHLOROTHALONIL	ug/l	0.1	8	<0.006	<0.006	<0.006	0
CHLORTOLURON	ug/l	0.1	8	<0.005	0.00675	0.007	0
CLOPYRALID	ug/l	0.1	8	<0.011	0.01163	0.016	0
CLOSTRIDIUM PERFRINGENS	Number/100ml	0	8	0	0	0	0
COLIFORM BACTERIA	Number/100ml	0	364	0	0	0	0
COLONY COUNT @ 22 C	Number/1ml	No Abnormal Change	365	0	0.14795	4	0
CONDUCTIVITY	uS/cm	2500	156	351	455.85256	675	0
CYANIDE	ugCN/l	50	8	<1.2	<1.2	<1.2	0
CYPROCONAZOLE	ug/l	0.1	8	<0.006	0.00688	0.007	0
DICAMBA	ug/l	0.1	8	<0.012	<0.012	<0.012	0
DICHLORPROP	ug/l	0.1	8	<0.01	<0.01	<0.01	0
DIELDRIN	ug/l	0.03	8	<0.009	<0.009	<0.009	0
DIFLUFENICAN	ug/l	0.1	8	<0.009	<0.009	<0.009	0
E.COLI	Number/100ml	0	364	0	0	0	0
EPOXICONAZOLE	ug/l	0.1	8	<0.005	0.00513	0.006	0
FENPROPIMORPH	ug/l	0.1	8	<0.01	<0.01	<0.01	0
FLUFENACET	ug/l	0.1	8	<0.008	<0.008	<0.008	0
FLUORIDE	mgF/l	1.5	8	0.05	0.0775	0.09	0
FLUOROXYPYR	ug/l	0.1	8	<0.008	<0.008	<0.008	0
FLUTRIAFOL	ug/l	0.1	8	<0.005	<0.005	<0.005	0
FLUXAPYROXAD	ug/l	0.1	8	<0.009	0.00913	0.01	0
FREE CHLORINE	mg/l as Cl2		367	0.16	0.87052	1.55	0
GLYPHOSATE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
GROSS ALPHA	Bq/l	0.1	8	<0.018	0.02538	0.034	0
GROSS BETA	Bq/l	1	8	0.096	0.13888	0.204	0
HEPTACHLOR	ug/l	0.03	8	<0.005	<0.005	<0.005	0

**BURHAM WSW**

Parameter Name	Units	Regulatory Limit (PCV)	No. of Samples	Minimum Result	Average Result	Maximum Result	PCV Breaches
HEPTACHLOR EPOXIDE	ug/l	0.03	8	<0.007	<0.007	<0.007	0
ISOPROTURON	ug/l	0.1	8	<0.005	<0.005	<0.005	0
LINURON	ug/l	0.1	8	<0.009	0.00988	0.01	0
MCPA	ug/l	0.1	8	<0.006	<0.006	<0.006	0
MECOPROP	ug/l	0.1	8	<0.009	<0.009	<0.009	0
MEPIQUAT CHLORIDE	ug/l	0.1	8	<0.004	0.005	0.008	0
MERCURY	ugHg/l	1	8	<0.04	0.045	0.06	0
METALDEHYDE	ug/l	0.1	8	<0.006	0.00688	0.007	0
METAZACHLOR	ug/l	0.1	8	<0.005	0.00588	0.006	0
NITRITE	mgNO2/l	0.5	8	<0.002	0.00275	0.003	0
PENDIMETHALIN	ug/l	0.1	8	<0.009	<0.009	<0.009	0
PESTICIDES - TOTAL SUBSTANCES	ug/l	0.5	8	0	0.00513	0.025	0
PICLORAM	ug/l	0.1	8	<0.016	<0.016	<0.016	0
PIRIMICARB	ug/l	0.1	8	<0.016	<0.016	<0.016	0
PROPICONAZOLE	ug/l	0.1	8	<0.007	0.00725	0.009	0
PROPYZAMIDE	ug/l	0.1	8	<0.009	0.00963	0.014	0
PROSULFOCARB	ug/l	0.1	8	<0.006	0.0095	0.01	0
QUINMERAC	ug/l	0.1	8	<0.006	0.00863	0.009	0
SPIROXAMINE	ug/l	0.1	8	<0.005	0.0055	0.009	0
SULPHATE	mgSO4/l	250	8	65.6	73.625	77.9	0
TEBUCONAZOLE	ug/l	0.1	8	<0.005	0.00513	0.006	0
TERBUTHYLAZINE	ug/l	0.1	8	<0.005	<0.005	<0.005	0
TOTAL CHLORINE	mg/l as Cl2		367	0.4	0.98499	1.65	0
TOTAL ORGANIC CARBON	mgC/l	No Abnormal Change	8	<0.7	1.9175	2.65	0
TRIALATE	ug/l	0.1	8	<0.006	<0.006	<0.006	0
TRICLOPYR	ug/l	0.1	8	<0.016	<0.016	<0.016	0
TURBIDITY	NTU	1	367	<0.13	0.16621	0.49	0